



#2 Gravel

Project:
 Location:
 Customer:
 Track #:

Sieve	Wt. Ret.	% Ret.	% Pass.	Low Lim.	Upp. Lim.
2" (50mm)	0	0	100	100	100
1 1/2" (37.5mm)	780	4	96	90	100
1" (25.0mm)	17406	88	12	5	40
3/4" (19.0mm)	19519	98	2	0	15
3/8" (9.5mm)	19665	99	1	0	5
Pan	19885				

Grading Limits Are In Accordance With Sec. 200-1.3 Of The Public Works "Green Book"

