



Type 2 Aggregate Slurry Grading Results

Project:
 Location:
 Customer:
 Track #:

Sieve	Wt. Ret.	% Ret.	% Pass.	Green Book Spec.		Caltrans Spec	
				Low Lim.	Upp. Lim.	Low Lim.	Upp. Lim.
3/8" (9.5mm)	0	0	100	100	100	100	100
#4 (4.75mm)	1	0	100	90	100	94	100
#8 (2.36mm)	57	11	89	65	90	65	90
#16 (1.18mm)	183	36	64	45	70	40	70
#30 (600um)	281	56	44	30	50	25	50
#50 (300um)	349	69	31	18	36	-	-
#100 (150um)	430	85	15	10	24	-	-
#200 (75um)	470	93	7	5	15	5	15
Pan	503	S.E. 68					

